

Fire Department Water Tanker Shuttle Accreditation

Presented To: Selwyn Township

ACCREDITED FIRE STATIONS

F.S. #1 Bridgenorth (7)

F.S. #2 Lakefield (7)

F.S. #3 Young's Point (7)

F.S. #4 Curve Lake (7)

F.S. #5 Ennismore (7)

Date Test Passed: September 14th 2019

Flow Achieved: 415 I.G.P.M. 1,890 LITERS/MIN.

Two (2) Hour Test Time



Signed: Elaine Rose
Elaine Rose
Partner

This Certificate Expires on: September 1st 2024