

2025 Summary Report for Municipalities

As required by Schedule 22 of Ontario Regulation 170/03

Lakefield Water Treatment Plant

1 January 2025 – 31 December 2025



Municipal Drinking Water Licence:	149-102; issue number 8
Drinking Waterworks Permit:	149-202; issue number 6
Municipal Waterworks Number:	220000488

Reported to Council on March 24th, 2026

Capability of Water System

Annual summary of water delivered in 2025:

Month	Average Day (m ³ / day)	Maximum Day (m ³ / day)	Peak Flows (L / min)
January	1005.1	1223.2	849.4
February	1197.1	1432.6	994.9
March	1137.2	1516.5	1053.1
April	1190.0	1566.3	1087.7
May	1366.5	1869.5	1298.3
June	1548.6	2126.4	1476.7
July	2005.5	2333.8	1620.7
August	1686.7	2448.0	1700.0
September	1327.3	1761.9	1223.5
October	1119.0	2868.4	1991.9
November	972.9	1195.1	829.9
December	1043.7	1326.5	921.2
Municipal Licence Rated Capacity		3,594.24 m ³ /day	
Maximum Taken per day (What Permit to Take Water allows: Permit # 5485- BGRST)		3,594.24 m ³ /day	2,500 L/min

The Municipal Drinking Water Licence rates the water treatment plant at 3,594.24 m³/day. There were no exceedances of this rating in 2025. The Max Day usage, which occurred on Oct 9th, 2025, represents 79.8% of the Municipal License Rated Capacity.

Submission of this Report

Schedule 22, section 22-2(1) of O. Reg. 170/03 under the Safe Drinking Water Act requires this report be submitted to the Township of Selwyn Council. The Report to Council was given on March 24, 2026.

Period Covered by this Report

Schedule 22, section 22-2(1) of O. Reg. 170/03 under the Safe Drinking Water Act requires this report cover the period of the preceding calendar year, from January 1 to December 31, 2025.

Failure to Meet Requirements of the Safe Drinking Water Act and Regulations

There are no known failures to meet the requirements of the Safe Drinking Water Act, 2002 or any current regulation made under this Act for the period covered by this report.

Failure to Meet Requirements of the Municipal Drinking Water Licence

There are no known failures to meet the requirements of the terms and conditions of the applicable Municipal Drinking Water Licence for the period covered by this report.

Failure to Meet Requirements of Provincial Officer Orders

There were no Provincial Officer's Orders issued during the period covered by this report. There are currently no known failures to meet the requirements of the terms and conditions of any Provincial Officer's Orders.

This report has been prepared by Anita Schoenleber, Township of Selwyn, Water and Wastewater Supervisor for the Township of Selwyn Operating Authority.

Anita Schoenleber
Water and Wastewater Supervisor
Township of Selwyn