

2025 Summary Report for Municipalities

As required by Schedule 22 of Ontario Regulation 170/03

Woodland Acres Subdivision Distribution System

1 January 2025 – 31 December 2025



Municipal Drinking Water Licence:	149-101; issue number 6
Drinking Waterworks Permit:	149-201; issue number 4
Municipal Waterworks Number:	210001503

Reported to Council on March 24th, 2026

Capability of Water System

Summary of water supplied to the system in 2025:

Month	Average Day (m ³ / day)	Monthly Total (m ³)
January	101.7	3154
February	85.7	2399
March	83.8	2598
April	75.8	2273
May	85.7	2657
June	105.7	3170
July	157.6	4887
August	210.0	6504
September	133.1	3993
October	106.0	3283
November	84.9	2546
December	115.5	3579
Municipal Licence Rated Capacity	Not applicable	Not applicable

The Woodland Acres Subdivision Distribution System receives treated water from the City of Peterborough's municipal drinking water system.

Submission of this Report

Schedule 22, section 22-2(1) of O. Reg. 170/03 under the Safe Drinking Water Act requires this report be submitted to the Township of Selwyn Council.

Period Covered by this Report

Schedule 22, section 22-2(1) of O. Reg. 170/03 under the Safe Drinking Water Act requires this report cover the period of the preceding calendar year, from January 1 to December 31, 2025.

Failure to Meet Requirements of the Safe Drinking Water Act and Regulations

There are no known failures to meet the requirements of the Safe Drinking Water Act, 2002 or any current regulation made under this Act for the period covered by this report.

Failure to Meet Requirements of the Municipal Drinking Water Licence

There are no known failures to meet the requirements of the terms and conditions of the applicable Municipal Drinking Water Licence for the period covered by this report.

Failure to Meet Requirements of Provincial Officer Orders

There were no Provincial Officer's Orders issued during the period covered by this report. There are currently no known failures to meet the requirements of the terms and conditions of any Provincial Officer's Orders.

This report has been prepared by Anita Schoenleber, Township of Selwyn, Water and Wastewater Supervisor for the operating authority.

Anita Schoenleber
Water and Wastewater Supervisor
Township of Selwyn