

Annual Report

FOR

WOODLAND ACRES SUBDIVISION DISTRIBUTION SYSTEM Section 11 of Ontario Regulation 170/03

PERIOD: January 1, 2025 – December 31, 2025



February 28, 2026
MECP Drinking Water System Number: 210001503

Drinking-Water System Number:	210001503
Drinking-Water System Name:	Woodland Acres Subdivision Distribution System
Drinking-Water System Owner:	Township of Selwyn
Drinking-Water System Category:	Water Distribution Class 1
Period being reported:	January 1, 2025 – December 31, 2025

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [X]</p> <p>Is your annual report available to the public no charge on a web site on the Internet? Yes [X] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>Township of Selwyn Office 1310 Centre Line Selwyn, ON K9J 6X5 www.selwyntownship.ca</p> </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <div style="border: 1px solid black; padding: 2px; width: 100px; text-align: center;">N/A</div> </p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Not applicable</p> <p>Number of Interested Authorities you report to: <div style="border: 1px solid black; padding: 2px; width: 100px; text-align: center;">N/A</div> </p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Not applicable</p>
---	---

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:
Not applicable

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?
Not applicable

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method

Describe your Drinking-Water System

The Woodland Acres Distribution System is owned and operated by the Township of Selwyn and generally consists of three elements:

1. Drinking Water Supply

The Woodland Acres Water Distribution System's water supply is from the City of Peterborough's municipal drinking water system. The Peterborough water system (MECP # 220000497) and the Annual Report for that system may be viewed on the City of Peterborough Website www.peterborough.ca

2. Water Pumping Station

There is a water booster pumping station at 218 Woodward Avenue, Township of Selwyn.

3. Water Distribution Piping System

The water distribution system consists of approximately 4,651 meters of pipe (water mains), 26 hydrants and 334 individual water services.

List all water treatment chemicals used over this reporting period:

None required

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
None					

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	n/a	n/a	n/a	n/a	n/a
Treated	n/a	n/a	n/a	n/a	n/a
Distribution	158	0-0	0-0	67	0-57

n/a means Not Applicable

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)	Unit of Measure	<i>NOTE: For continuous monitors use 8760 as the number of samples.</i>
Chlorine	8760	0.46-2.31	mg/L	

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
None				

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Nitrite	Feb 19, 2025	0.003 <MDL	mg/L	No
	May 27, 2025	0.003 <MDL		
	Sept 23, 2025	0.003 <MDL		
	Nov 25, 2025	0.003 <MDL		
Nitrate	Feb 19, 2025	0.154	mg/L	No
	May 27, 2025	0.193		
	Sept 23, 2025	0.052		
	Nov 25, 2025	0.002		

Summary of lead testing under Schedule

15.1 during this reporting period

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Unit of Measure	Number of Exceedances
Plumbing	Not required			
Distribution	2	0.16-1.69	mg/L	0

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
THM (NOTE: show latest annual average)	Annual Average	70.8	µg/L	No
HAA (NOTE: show latest annual average)	Annual Average	51.4	µg/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Not applicable			